



CCR Fugitive Dust Control Report - 2025

Morrow Hydroelectric Project Morrow CCR Impoundment STS Hydropower, LLC

40 CFR 257.80 (c)

January 6, 2026

Revision: 0



Table of Contents

1 Introduction..... 3
 1.1 Purpose of this Report..... 3
 1.2 Summary of Control Actions and Corrective Measures..... 3
2 Conclusion 3



1 Introduction

1.1 Purpose of this Report

The purpose of the Annual Coal Combustion Residuals (CCR) Fugitive Dust Control Report is to document the actions taken to control fugitive dust, receipt of any citizen complaints, and the corrective measures taken in response at the Morrow CCR Impoundment in 2025. This report was prepared in accordance with 40 CFR Part 257.80 (c).

1.2 Summary of Control Actions and Corrective Measures

This is the first Annual CCR Fugitive Dust Control Report for the Morrow CCR Impoundment. No specific actions beyond the controls described in the CCR Fugitive Dust Control Plan (Plan) were required to control potential fugitive dust from being generated at the CCR Impoundment. No citizen complaints have been recorded regarding the generation of fugitive dust at the CCR Impoundment and therefore no corrective measures have been needed. However, an inspection of the impoundment conducted on November 10, 2025 for the annual PE inspection required by 40 CFR 257.83(b) identified one Fugitive Dust Control Plan speed limit sign along the southern perimeter road of the impoundment that had vegetation overgrowth and was not clearly visible and legible to vehicular traffic. The Qualified Person inspection requirements in 40 CFR 257.83(a) will be revised accordingly to include this issue as a regular inspection item.

2 Conclusion

STS will continue to implement and evaluate the effectiveness of the Plan for the Morrow CCR Impoundment, record and subsequently address citizen complaints as required by the Plan, and routinely complete and retain CCR Fugitive Dust Control Reports.